

CME Booster

End-of-Life Information

Grundfos CME Booster must be disposed of according to local regulations by using a public or private waste collection service. If this is not possible, contact the nearest Grundfos company or service workshop.

Safety Risk

- Safety related to materials used
There is no risk for people during the disassembly process posed by the materials used for the product.
- Safety related for handling the product
There is no risk for people when handling the product.

Disassembly of the Product

The main materials of the components are:

- Copper
- Iron
- Aluminium
- Electronic scrap
- Composite materials

and can therefore be recycled to a large extent – depending on the national possibilities for recycling.

The product is assembled using screws and bolts and can be disassembled with standard tools


Designation	Name	Material	Special Disassembly Consideration
1	Flange	Aluminium or cast iron	
2	Bearings	Steel	
3	Rotor	Copper, Iron, Aluminium	
4	Stator housing	Aluminium or cast iron,copper, iron	The stator is shrink fitted in the motor housing
5	Screws	Steel	
6	Fan	PC/ABS or PC/PBT or PC or Aluminium	
7	Fan cover	PC/ABS or PC/PBT or PC or sheet metal	
8	Flange	Cast iron	
9	Inlet part	Cast iron	
10	Chamber	Stainless steel	
11	Impeller	Stainless steel	
12	Discharge part	Cast iron	
13	Controller box	see below	
13a	Foil	Polyester	
13b	Terminal box	Composite or cast iron or aluminium	

	cover		
13c	Printed circuit board	Electronic scrap	
13d	Isolation cover	PET 30% glass filling	
13e	Lower cover	Aluminium	
Additional materials:		Screws, gaskets, cable etc.: Various materials less than 5% of weight.	

13a




13b



13c



13d



13c



13c



13e

